



Investigative Energy Audit
For
Tyonek Tribal Center



Prepared For
Native Village of Tyonek

August 30, 2017

Prepared By: Kevin Ulrich & Kelli Whelan

**ANTHC-DEHE
4500 Diplomacy Drive
Anchorage, AK 99508**

Table of Contents

PREFACE	2
ACKNOWLEDGMENTS	2
OVERVIEW	3
ENERGY BASELINE	3
Table 1: Predicted Annual Energy Use for the Tyonek Tribal Center.....	3
PROPOSED ENERGY EFFICIENCY MEASURES (EEM)	3
FACILITY DESCRIPTION	4
PROJECT FINANCING	6
MEASUREMENT AND VERIFICATION	7
Appendix A –Energy Billing Data.....	8
Appendix B – Energy Audit Report – Project Summary	9
Appendix C – Actual Fuel Use versus Modeled Fuel Use	10
Appendix D - EUI Calculation Details	11
Appendix E – Materials List and Labor Estimation.....	13
Appendix F – Materials Specifications	14

PREFACE

The purpose of this report is to provide guidance in reducing facility operating costs and enhance the sustainability of this community. The report assesses the current energy usage of the facility, provide options for reducing the amount of energy used, and evaluate the cost vs. benefit of each option.

Discussions of site specific concerns, financing options, general facility information, and an Energy Efficiency Action Plan are also included in this report.


ACKNOWLEDGMENTS

The ANTHC Rural Energy Initiative gratefully acknowledges the assistance of President Arthur Standifer, Tribal Administrator Sandi Kroto, and Tyonek Native Corporation Administrator Tonya Kaloa.

OVERVIEW

This report was prepared for the Native Village of Tyonek. The scope of the audit focused on the Tyonek Tribal Center and includes an analysis of building occupancy schedules, building shell, heating systems, heating and ventilations systems, domestic hot water, lighting, and other electrical loads. The Tyonek Tribal Center was constructed around 1960 and is approximately 4,900 square feet. The building serves as a common area for large community events and also houses the offices for the Native Village of Tyonek.

Annual Energy Costs by Fuel Type



ENERGY BASELINE

Based on unsubsidized electricity and fuel oil prices in effect at the time of the audit, the total predicted energy costs are \$13,055 per year. This includes \$6,809 for electricity and \$6,246 for #1 fuel oil.

Table 1 lists the predicted annual energy usage before and after the proposed retrofits for the Tyonek Tribal Center.

Table 1: Predicted Annual Energy Use for the Tyonek Tribal Center

Predicted Annual Fuel Use			Total Energy Savings	Total Cost Savings
Fuel Use	Existing Building	With Proposed Retrofits		
Electricity	46,872 kWh	32,996 kWh	13,876 kWh	\$2,220
#1 Oil	1,315 gallons	1,041 gallons	274 gallons	\$1,302

PROPOSED ENERGY EFFICIENCY MEASURES (EEM)

Table 2 below summarizes the energy efficiency measures analyzed for the Tyonek Tribal Center. Listed are the estimates of the annual savings, installed costs, and two different financial measures of investment return. All costs assume that local labor will be used with no additional cost associated for travel or administrative tasks.

Table 2: Priority List – Energy Efficiency Measures

Priority	Feature	Improvement Description	Annual Energy Savings	Installed Cost	Savings to Investment Ratio, SIR ¹	Simple Payback (Years) ²	CO ₂ Savings
High	Setback Thermostat: Tribal Center	Install new programmable thermostats for the forced air heating system and program an unoccupied temperature setback of 55 deg. F.	\$2,029	\$1,000	26.26	0.5	11,369.3
High	Other Electrical: Coffee Maker	Unplug coffee maker at the end of the day when not in use.	\$12	\$20	4.52	1.7	184.7

Priority	Feature	Improvement Description	Annual Energy Savings	Installed Cost	Savings to Investment Ratio, SIR ¹	Simple Payback (Years) ²	CO ₂ Savings
Medium	Lighting: Offices	Replace with new, direct-wire LED equivalent lamps.	\$32	\$300	1.26	9.3	251.1
Medium	Lighting: Office Lights - Recently Converted	Replace with new, direct-wire LED equivalent lamps.	\$39	\$360	1.26	9.3	301.3
Medium	Lighting: Common Room Outer Ring	Replace with new, direct-wire LED equivalent lamps.	\$139	\$1,440	1.13	10.4	1,084.8
Medium	Above-Grade Wall: Walls	Add spray foam insulation to the rim joist of the walls and in between the logs within the structure. The effects of this retrofit are represented in both the wall insulation and air tightening categories.	\$382	\$7,983	1.06	20.9	2,139.0
Medium	Air Tightening	Add spray foam insulation to the rim joist of the walls and in between the logs within the structure. The effects of this retrofit are represented in both the wall insulation and air tightening categories.	\$346	\$3,000	1.04	8.7	1,938.5
Low	Lighting: Hallway, Office Lights	Replace with new, direct-wire LED equivalent lamps.	\$76	\$1,080	0.82	14.2	591.8
Low	Lighting: Office Lights	Replace with new, direct-wire LED equivalent lamps.	\$41	\$720	0.66	17.8	316.3
Low	Heating and Ventilation Systems	Clean air furnace and tune burners and fuel injection for optimal operation.	\$157	\$2,000	0.47	12.8	2,832.2
Low	Lighting: Restroom Fluorescents	Replace with new, direct-wire LED equivalent lamps.	\$2	\$120	0.22	53.6	17.5
Low	Lighting: Storage Room Incandescents	Replace with new, direct-wire LED equivalent lamps.	\$1	\$80	0.19	63.5	9.8
Low	Lighting: Basement CFL 22W	Replace with new, direct-wire LED equivalent lamps.	\$0	\$20	0.18	64.4	2.4
Low	Lighting: Basement Incandescent 75W	Replace with new, direct-wire LED equivalent lamps.	\$2	\$40	0.18	26.1	12.0
TOTAL			\$3,257	\$18,163	2.35	5.6	21,050.7

FACILITY DESCRIPTION

Building Occupancy Schedules

The building is occupied from 9:00AM to 5:00PM five days per week as standard operating hours for the offices. The building is also used on weekends and during some evenings for community gatherings.

Building Shell

The building is a log structure with a crawl space beneath the flooring. There is a central large circular room with three wings of the building branching out from the center. The center room is used as the common area of the center. Two of the three wings hold office space and meeting rooms while the third wing holds a kitchen, restrooms, and storage. The wings all have attic spaces while the center room has a high ceiling.

The building has 67 individual windows, each of which is double pane glass with wood framing. There is approximately 1,053 square feet of window space in the building.

There are two entrances to the building. The center entrance is a set of wood double-doors with half-lite windows. The side entrance is a single wood door at the end of one of the building wings.

Heating Systems

The heating systems used in the building are:

Lennox Forced Air Heater

Fuel Type: #1 Oil
Input Rating: 142,000 BTU/hr
Steady State Efficiency: 80 %
Idle Loss: 0.5 %
Heat Distribution Type: Air

Electric Hot Water Heater

Fuel Type: Electricity
Input Rating: 0 BTU/hr
Steady State Efficiency: 95 %
Idle Loss: 0 %
Heat Distribution Type: Water
Boiler Operation: All Year

Electric Heaters (5 total)

Fuel Type: Electricity
Input Rating: 0 BTU/hr
Steady State Efficiency: 95 %
Idle Loss: 0 %
Heat Distribution Type: Air

Domestic Hot Water System

There is a 50-gallon hot water storage tank with the electric hot water heater. The heater is manufactured by the American Water Heater Company and is rated for 4500 Watts.

Lighting

Table 3: Lighting Information in the Tyonek Tribal Center

Room	Bulb Type	Fixtures	Bulbs per Fixture	Annual Usage (kWh)
Common Room – Outer Ring	Fluorescent T12 8ft. 96 W	12	2	2,371
Common Room – Main Lights	LED 8 Watt Screw-in Lamps	11	1	174
Hallway, Office Lights	Fluorescent T12 4ft. 40 W	9	4	1,577
Office Lights – T12	Fluorescent T12 4ft. 40 W	5	2	523
Office Lights – T8	Fluorescent T8 4ft. 32 W	6	4	980
Office Lights – Recently Converted	Fluorescent T12 4ft. 40 W	6	2	628
Basement CFL 22W	Fluorescent CFL Spiral 23 W	1	1	4
Basement Incandescent	Incandescent A Lamp 75 W	1	1	14
Restrooms	Fluorescent T12 4ft. 40 W	1	4	26
Storage Room	Incandescent A Lamp 40 W	2	1	15

The Native Village of Tyonek has been in the process of adding energy efficiency upgrades to this facility. There are office lights that have been recently converted to LED lamps. These have been modeled as the original fluorescent lamps in order to accurately portray the building during the time period that the electric usage data covers.

Electrical Equipment

Table 4: Major Electrical Equipment in the Tyonek Tribal Center

Equipment	Rating (Watts)	Annual Usage (kWh)
Refrigerator – Common Room	~ 225	2,000
Refrigerators (2) - Kitchen	~ 225 each	4,000
Chest Freezer	460	4,032
Microwave	1,800	329
Coffee Maker	1,575	1,530
Bass Guitar Speaker	400	84
Karaoke Machine	10	2
Large Office Printers (2)	1,470 each	269
Office Computers (5)	~ 250	2,374
Small Office Printer	27	3
Electric Range	~ 3,000	1,534

PROJECT FINANCING

The total estimated cost of the recommended EEM’s \$18,163. The payback for the implemented EEM’s is approximately 5.6 years. ANTHC is willing to assist the community with acquiring funds to complete the scope of work recommended in this energy audit.

There are several options for financing energy efficiency projects within the State of Alaska. These include the use of grants, loans, and other funding opportunities. Below is some information on potential funding opportunities.

Energy Efficiency Revolving Loan Program – This is a loan administered by the Alaska Housing Finance Corporation (AHFC) for use by any applicant who is also the owner of the building where the work will take place. It provides a loan for permanent energy-efficiency projects with a completion window of one year.

Sustainable Energy Transmission and Supply Program – This is a loan administered by the Alaska Energy Authority (AEA) for a government, business, or other organized body of people. It provides a loan for energy-efficiency or power transmission or distribution projects.

USDA-RD Communities Facilities Direct Loan & Grant Program - This is a loan or grant provided by the US Department of Agriculture – Rural Development (USDA-RD) for any essential community facility in a rural area. It provides a loan or grant to develop essential community facilities with upgrades or equipment for improvement.

MEASUREMENT AND VERIFICATION

The results of these recommended measures can be measured through the collection of energy use data through the monthly bills provided by the local electric utility and the local fuel oil supplier. Collecting data and performing a historical comparison is the simplest method of validating the energy and cost savings seen by the measures. Additionally, active remote monitoring systems are available that can collect and store data regarding energy and fuel usage. These systems allow the user to track the usage in real time and can be shared more easily with partners across the state.

APPENDICES

Appendix A –Energy Billing Data

The table below shows the fuel and electricity data used during the energy modeling process to confirm the accuracy of the energy distribution. Electricity data was obtained from Chugach Electric. Fuel data was obtained from the Native Village of Tyonek and the distribution was approximated for the energy audit.

Month	Fuel Oil Use (gallons)	Electricity Use (kWh)
January	238	7,520
February	190	5,840
March	155	6,600
April	69	4,520
May	35	1,640
June	5	880
July	5	880
August	5	1,400
September	25	1,760
October	145	2,080
November	200	4,080
December	235	7,560

Appendix B – Energy Audit Report – Project Summary

ENERGY AUDIT REPORT – PROJECT SUMMARY	
General Project Information	
PROJECT INFORMATION	AUDITOR INFORMATION
Building: Tyonek Tribal Center	Auditor Company: ANTHC-DEHE
Address: P.O. Box 82009	Auditor Name: Kevin Ulrich and Kelli Whelan
City: Tyonek	Auditor Address: 4500 Diplomacy Drive
Client Name: Arthur Standifer	Anchorage, AK 99508
Client Address: P.O. Box 82009	Auditor Phone: (907) 729-3237
Tyonek, AK 99682	Auditor FAX:
Client Phone: (907) 583-2111	Auditor Comment:
Client FAX:	
Design Data	
Building Area: 4,905 square feet	Design Space Heating Load: Design Loss at Space: 85,113 Btu/hour with Distribution Losses: 85,113 Btu/hour Plant Input Rating assuming 82.0% Plant Efficiency and 25% Safety Margin: 129,746 Btu/hour Note: Additional Capacity should be added for DHW and other plant loads, if served.
Typical Occupancy: 0 people	Design Indoor Temperature: 65 deg F (building average)
Actual City: Tyonek	Design Outdoor Temperature: -1.2 deg F
Weather/Fuel City: Tyonek	Heating Degree Days: 9,722 deg F-days
Utility Information	
Electric Utility: Chugach Electric	Average Annual Cost/kWh: \$0.145/kWh

Annual Energy Cost Estimate						
Description	Space Heating	Water Heating	Lighting	Refrigeration	Other Electrical	Total Cost
Existing Building	\$9,407	\$277	\$889	\$845	\$1,431	\$13,055
With Proposed Retrofits	\$6,536	\$277	\$558	\$845	\$1,378	\$9,798
Savings	\$2,872	\$0	\$331	\$0	\$54	\$3,257


Building Benchmarks			
Description	EUI (kBtu/Sq.Ft.)	EUI/HDD (Btu/Sq.Ft./HDD)	ECI (\$/Sq.Ft.)
Existing Building	68.0	6.99	\$2.66
With Proposed Retrofits	51.0	5.24	\$2.00

EUI: Energy Use Intensity - The annual site energy consumption divided by the structure's conditioned area.
 EUI/HDD: Energy Use Intensity per Heating Degree Day.
 ECI: Energy Cost Index - The total annual cost of energy divided by the square footage of the conditioned space in the building.


Appendix C – Actual Fuel Use versus Modeled Fuel Use

The graphs below show the modeled energy usage results of the energy audit process compared to the actual energy usage report data. The model was completed using AkWarm modeling software. The orange bars show actual fuel use, and the blue bars are AkWarm’s prediction of fuel use.


Annual Energy Use



Electricity Use



#1 Fuel Oil Use



Appendix D - EUI Calculation Details

Electricity for the residential, commercial, and public facilities is provided by the Chugach Electric Association.

The average cost for each type of fuel used in this building is shown below in Table 5. This figure includes all surcharges, subsidies, and utility customer charges:

Table 5: Energy Cost Rates for each Fuel Type.

Average Energy Cost	
Description	Average Energy Cost
Electricity	\$ 0.16/kWh
#1 Oil	\$ 4.75/gallons

Table 6 shows the calculated results for the building Energy Use Index (EUI), which determines the total energy usage for a type of building for comparison with other buildings of the same type. This allows the user to determine the relative energy use of a building in relation to others of the same type or use.

Table 6: EUI Building Calculations for the Tyonek Tribal Center

Energy Type	Building Fuel Use per Year	Site Energy Use per Year, kBTU	Source/Site Ratio	Source Energy Use per Year, kBTU
Electricity	46,872 kWh	159,974	3.340	534,312
#1 Oil	1,315 gallons	173,569	1.010	175,305
Total		333,542		709,616
BUILDING AREA		4,905	Square Feet	
BUILDING SITE EUI		68	kBTU/Ft ² /Yr	
BUILDING SOURCE EUI		145	kBTU/Ft²/Yr	
* Site - Source Ratio data is provided by the Energy Star Performance Rating Methodology for Incorporating Source Energy Use document issued March 2011.				

Table 7 shows information on common energy use benchmarks used to characterize the efficiency of a building.

Table 7: Building Benchmarks for the Tyonek Tribal Center

Building Benchmarks			
Description	EUI (kBtu/Sq.Ft.)	EUI/HDD (Btu/Sq.Ft./HDD)	ECI (\$/Sq.Ft.)
Existing Building	68.0	6.99	\$2.66
With Proposed Retrofits	51.0	5.24	\$2.00
<p>EUI: Energy Use Intensity - The annual site energy consumption divided by the structure's conditioned area. EUI/HDD: Energy Use Intensity per Heating Degree Day. ECI: Energy Cost Index - The total annual cost of energy divided by the square footage of the conditioned space in the building.</p>			

Appendix E – Materials List and Labor Estimation

Table 8 & 9: Materials List and Cost Estimation for Tyonek Tribal Center EEM's

Energy Retrofit	Required Materials	Quantity	Cost per Item	Total Materials Cost
Lighting – T8 4ft. Replacements	T8 4ft. LED equivalent lamps	82	\$15	\$1,230
Lighting – Screw-in Bulb Replacements	LED 10W Screw-in Bulbs	4	\$25	100
Lighting – T8 8ft. Replacements	T8 8ft. LED equivalent lamps	24	\$30	\$720
Air Tightening	Weather Stripping, Spray Foam, Window Film	1	\$2000	\$2000
Air Furnace Tuning and Controls	Burner, Controls	1	\$500	\$500
Setback Thermostats	Thermostats	1	\$200	\$200

Category	Cost (\$)
Labor	8,322
Travel	3,050
Materials	4,750
Freight	713
Indirect	1,683
Total	18,517

Appendix F – Materials Specifications

Robertshaw®

9701i2

DELUXE
PROGRAMMABLE
THERMOSTAT



GAS



ELECTRIC




OIL



HEAT PUMP

Menu Driven Display 1 Heat / 1 Cool



Programming Made Even Easier

Do you want to spend less time installing and setting up thermostats?

The new 9701i2 makes installation even easier with our new Setup Wizard. The Setup Wizard allows you to spend 50% less time setting up the thermostat over competitive models. Plus everything is in plain language so there are no complicated codes or button combinations to memorize.

We've also made programming even easier for your customers. Menus are easier to navigate. We've even added additional convenience features such as Automated Time adjustment for Daylight Saving Time, along with new indoor air quality reminders.

The new 9701i2 is so user friendly, it sets a higher standard in efficiency and simplicity for programmable thermostats. It is truly programming made even easier.

Robertshaw - *Simply the Right Choice™*

Features and Benefits

Would You Like To Run the Setup Wizard?

No Yes

Set-up Wizard

Helps speed through the installation process with step-by-step setup and programming instructions.

Select Language

English
Español
Français

Back Next

Trilingual Display Option

Set to your customers' language of choice – English, Spanish or French

Mon To Sun Program

		HEAT	COOL
Wake	6:00 AM	70	78
Morn	8:00 AM	62	65
Eve	5:00 PM	70	78
Night	10:00 PM	62	62
Exit		Select	

Convenient Displays

View a full day of programming at once for quick review or easy adjustment.

Tech Support

Model 9701i vX.X
ABC HEAT
555-1234
ROBERTSHAW
(800) 445-8299

Contractor ID Feature

Set it yourself or custom order with your information pre loaded. Your name and phone number remind your customers when service is needed.

Daylight Saving Time Adjustment

Automatically adjusts to correct time regardless of seasonal changes.

Adjustable Backlighting

Choose to have backlighting on at all times or only when programming. You can also adjust the brightness and contrast for improved readability.

Time of Day Zoning

When coupled with a remote sensor (part #9020i), you can control the temperature in remote locations given different scheduled events.

Three Levels of Security

Secure protection against unwanted changes to the programming menus, temperature or set-up functions with your own 4-digit PIN.

Auto Changeover

Automatically adjusts between heating and cooling cycles to maintain optimal comfort.

Worry-Free Memory Storage

Even during power outages, the thermostat maintains set point and programmed parameters.

Adjustable Temperature Offset

Change the displayed temperature from the actual sensed temperature.

Adjustable Temperature Differential

Maintains optimal customer comfort.

Intermittent Fan

Maintains optimal air filtration and circulation with minimal energy use.

An ISO 9001 – 2008 Certified Company

California Title 24 Compliant




5 Year
Limited
Warranty

24V AC POWERED

Robertshaw®

9701i2 DELUXE PROGRAMMABLE THERMOSTAT

Terminal Designations



Technical Specifications

Electrical Rating	24 Volt AC (18-30 VAC) 1 amp maximum load per terminal (relay outputs) 3 amp total maximum load (all terminals combined)
Temperature Control Range	45°- 90°F (7°- 32°C)
Accuracy	+/-1.0°F (+/-0.5°C)
Power Source	24 VAC
Auto Changeover Deadband	Selectable 2° to 8°F
Temporary Temperature Override	3 hour maximum or next setpoint
Remote Sensor Capable	1 indoor and 1 outdoor sensor
System Configurations	Single-stage gas, oil or electric heating/cooling systems and single stage heat pump
Terminations	R, W1, Y1, B, O, G, C, IS, OS

Shipping Specifications

Indiv. Ctn. Dim.: 6.625" x 4.25" x 1.625"	Item 9020i and 9025i Remote Sensors
Master Ctn. Qty.: 6	Indiv. Ctn. Dim.: 2.625" x 1.5625" x 4.4375"
Master Ctn. Dim.: 9.25" x 5.625 x 7.5"	Master Ctn. Qty.: 6
Master Ctn. Cu. Ft.: .23	Master Ctn. Dim.: 5.625" x 5.125" x 5.125"
Master Ctn. Wt.: 3.5 lbs.	Master Ctn. Cu. Ft.: .09
Max. Pallet Qty.: 1260	Master Ctn. Wt.: .78 lbs.
Max. Pallet Wt.: 785 lbs.	

Replacement Chart

9701i2	
Braeburn®	5000
Honeywell	TH8110U1003
White-Rodgers	1F95-1271, 1F90-51, 1F90-71, 1F90-371, 1F97-51, 1F97-71, 1F97-371
Carrier	TC-PAC, TC-PHP, P274-1100, P374-1100, P474-1100
Lux	PSPA711

Verify specific application requirements before substitution.

Patent Information

This product is covered by one or more of the following U.S. patents. Foreign patent rights may be pending. 4967382, 5803357, 6502758, 7000849, D301207, D462940

invenSYS
Controls

191 E. North Avenue
Carol Stream Illinois 60188 USA
Customer Service Telephone 1.800.304.6563
Customer Service Facsimile 1.800.426.0804
HVACCustomerService@InvenSysControls.com

For Technical Service
Telephone 1.800.445.8299
Facsimile 1.630.260.7294
TechnicalService@InvenSysContrtols.com

InvenSys™, Robertshaw® and Simply the Right Choice™ are trademarks of InvenSys plc., its subsidiaries and/or affiliated companies. All other brands mentioned in this report may be the trademarks of their respective owners.

www.RobertshawTstats.com
www.InvenSysControls.com
©2009 InvenSys Controls 10/09 - 150-1978B




Optional Sensors:
9020i: REMOTE INDOOR
9025i: REMOTE OUTDOOR

Feature Comparison

	InvenSys i2-Series	Honeywell Vision Pro	Carrier Infinity	White-Rodgers 1F97-371
Menu Driven (Ease of Programming)	X			
Installation Wizard	X			
Displays Complete Program	X			
Adjustable Backlighting	X			
Cooling System Monitor	X			
Heating System Monitor	X			
Multi-Language	X			
1/2 Degree Resolution	X			
Time of Day Zoning	X			
5/2 Program	X			X
24 Hour Programming	X			X
7-Day Programming	X	X	X	
Large Display	X	X	X	
Adjustable Timed Override/Hold	X	X		
Automatic Daylight Saving Time Adjustment	X	X		
Adjustable Temperature Limits	X	X		
High/Low Balance Points	X	X		
LED Status Indicators	X	X		
Adjustable Differential	X	X		
Adjustable Compressor Short Cycle Protection	X	X		
Adjustable Residual Cooling	X	X		
Fossil Fuel Kit required on HP units	No	No	Yes	Yes
Battery Free Memory Retention	X		X	
Manual Override	X	X	X	X
Resume	X	X	X	X
Auto Changeover	X	X	X	X
Gas/Electric	X	X	X	X
Single Stage Heat Pump Compatible	X	X	X	X
Line Powered	X	X	X	X
Programmable Fan	X	X	X	X
Intermittent Fan	X		X	
°F and °C	X	X	X	X
12 or 24 Hour	X	X		X
Air Filter Monitor	X	X	X	X
Humidifier Pad Monitor	X	X	X	
UV Light Monitor	X	X	X	
Vacation Setting	X	X	X	X
O & B Terminals	X	X	Partial	X
Events per day	2, 4, 6	4	4	2, 4
Remote Outdoor Sensor	X	Combo	X	X
Remote Indoor Sensor	X		X	X
Energy Efficient Recovery	X	X	X	X
Pre-set Program	X	X	X	X
Hidden Service Level	X	X	X	
Security Key Pad	X			X
Temperature Recalibration	X	X	X	
Customizable Contractor ID	X			Factory Only

NOTE: Always keep the thermostat's vents clean and unobstructed.



1 Description

This programmable thermostat can be used to control an electric heating system such as an electric baseboard heater, a radiant ceiling, a radiant floor, a convector, etc.

The thermostat cannot be used under the following conditions:

- The resistive load is greater than 16.7 A
- The resistive load is less than 2 A
- The system is driven by a contactor or relay (inductive load)
- The system is a central heating system

SUPPLIED PARTS:

- One (1) thermostat
- Two (2) 6-32 screws
- Two (2) solderless connectors


2 Installation

TURN OFF POWER TO THE HEATING SYSTEM AT THE MAIN POWER PANEL TO AVOID ELECTRICAL SHOCK.

THE INSTALLATION MUST BE PERFORMED BY AN ELECTRICIAN.


- ▶ All cables and connections must conform to the local electrical code.
- ▶ Special CO/ALR solderless connectors must be used when connecting with aluminum conductors.
- ▶ Install the thermostat onto an electrical box.
- ▶ Install the thermostat about 5 feet high, on an inside wall facing the heater.
- ▶ Avoid locations where there are air drafts (such as the top of a staircase or an air outlet), dead air spots (such as behind a door), or direct sunlight.
- ▶ Do not install the thermostat on a wall that conceals chimney or stove pipes.
- ▶ The thermostat wires are not polarized; either wire can be connected to the load or to the power supply.

1




2 Connect the thermostat wires to the line wires and to the load wires using solderless connectors for copper wires.


2-wire installation



4-wire installation



3 Push any excess wire back into the electrical box.




NOTE: If necessary, before re-installing the front component, configure the thermostat (see section 3).

4 Return power to heating system.

3 Configuration

The configuration switches are on the back of the thermostat. The factory settings are indicated by the gray cells in the following table.



SW1	Early Start ^a	Off	On
SW2	Temperature / time format ^b	°C / 24-hour	°F / 12-hour
SW3	Cycle length ^c	15 seconds	15 minutes
SW4	Not used	-	-

- Early Start can be used in Automatic mode only. When this function is enabled, the thermostat calculates the optimal time to start heating in order to obtain the desired temperature by the set time. The thermostat re-assesses the start time daily based on the previous day's performance.
- If you change the temperature display format, the preset temperatures (☼, ☾ and ☰) will return to their default settings.
- 15-second cycles should be selected in most cases as it provides better temperature control. 15-minute cycles must be selected if you have a fan-equipped heater or if 15-second cycles causes light flickering (especially in rural regions).

4 Power-up

Upon power-up, the thermostat is in manual mode (☼) and displays the actual (ambient) temperature.

- Press the **Hour** and **Min** buttons to set the thermostat's clock.
- Press the **Day** button to set the day.

5 Temperature Setting

Setpoint

The thermostat normally displays the actual temperature. To view the setpoint, press the ▲ or ▼ button briefly. The setpoint will appear for the next 5 seconds.

To change the setpoint, press the ▲ or ▼ button until the desired temperature is displayed. To scroll faster, hold the button.

Using a preset temperature

The thermostat has 3 preset temperatures:

- Comfort temperature ☼
- Economy temperature ☾
- Vacation temperature ☰

Icon	Intended use	Factory setting
☼	Comfort (when at home)	21°C (70°F)
☾	Economy (when asleep or away from home)	16.5°C (62°F)
☰	Vacation (during prolonged absence)	10°C (50°F)

- To use the Comfort or Economy temperature, press the ☼ or ☾ button respectively. The corresponding icon will be displayed.
- To use the Vacation temperature, press both ☼ and ☾ buttons simultaneously. The ☰ icon will be displayed.

Storing a preset temperature

To store the Comfort or Economy temperature:

Set the desired temperature using the ▲ or ▼ button. Press and hold the appropriate button (☼ or ☾) for approximately 3 seconds until the corresponding icon is displayed. Press the **Mode** button.

To store the Vacation temperature:

Set the desired temperature using the ▲ or ▼ button. Press and hold both ☼ and ☾ buttons simultaneously for approximately 3 seconds until the ☰ icon is displayed. Press the **Mode** button.

6 Operating Modes

⌚ **Automatic** - The temperature is set according to the programmed schedule. To place the thermostat in this mode, press **Mode** until ⌚ is displayed. The icons of the current period and preset temperature are also displayed.

Temporary Bypass: If you modify the setpoint (by pressing the ▲, ▼, ☼ or ☾ button) when the thermostat is in automatic mode, the new setpoint will be used until the end of the current period. When the next period starts, the temperature set for that period becomes the new setpoint.

☼ **Manual** - The programmed schedule is not used. The temperature must be set manually. To place the thermostat in this mode:

- Press **Mode** until ☼ is displayed.
- Set the temperature using the ▲, ▼, ☼ or ☾ button.

7 Schedule

The schedule consists of 4 periods per day which represents a typical weekday. You can program the thermostat to skip the periods that do not apply to your situation. For example, you can skip periods 2 and 3 for the weekend.

Period	Description	Associated temperature preset
☼	Wake	☼
☾	Leave	☾
☼	Return	☼
☾	Sleep	☾

The Comfort (☼) temperature is used in periods 1 and 3 and the Economy (☾) temperature is used in periods 2 and 4. For example, when the period changes from 1 to 2, the setpoint automatically changes from Comfort setting (☼) to Economy setting (☾).

You can have a different program for each day of the week; i.e., each period can start at different time for each day of the week. The thermostat has been programmed with the following schedule.

Period	Setting	MO	TU	WE	TH	FR	SA	SU
☼	☼	6:00 AM	6:00 AM	6:00 AM	6:00 AM	6:00 AM	6:00 AM	6:00 AM
☾	☾	8:00 AM	8:00 AM	8:00 AM	8:00 AM	8:00 AM	--:--	--:--
☼	☼	6:00 PM	6:00 PM	6:00 PM	6:00 PM	6:00 PM	--:--	--:--
☾	☾	10:00 PM	10:00 PM	10:00 PM	10:00 PM	10:00 PM	10:00 PM	10:00 PM

To modify the schedule:

- Press **Pgm** to access the programming mode. Period 1 is selected.
- Press **Day** to select the day to program (hold for 3 seconds to select the entire week).
- Press **Hour** and **Min** to set the start time of the selected period, or press **Clear** if you want to skip the period (--:-- is displayed).
- Press **Pgm** to select another period, or press **Day** to select another day. Then repeat step 3.

5 Press **Mode** to exit the programming mode.

NOTE: If no button is pressed for 60 seconds, the thermostat will automatically exit the programming mode.

8 Power Outage

During a power outage, the settings are stored in memory. However, only the thermostat's clock must be re-adjusted if the power failure lasts more than 2 hours. When power comes back, the thermostat will return to the operating mode that was active prior to the power failure.

9 Troubleshooting

PROBLEM	SOLUTIONS
Thermostat is hot.	This condition is normal. Under normal operation, the thermostat housing can reach a temperature between 35°C (95°F) and 40°C (104°F).
Heater is always On.	The thermostat has not been correctly wired.
Thermostat indicates that heating is On, but the heater is not On.	The thermostat has not been correctly wired.
Wrong temperature is displayed.	The thermostat is exposed to air draft. Eliminate the draft. The sticker on the thermostat's screen has not been removed.
Wrong time is displayed.	The thermostat was without power for more than 2 hours.
Temperature does not change according to the programmed schedule.	Check that the thermostat is in Automatic mode. Check the schedule and clock settings.
Display disappears and reappears after a few minutes.	The thermal protection device on the heater is open. This can happen after a power failure or if the heater is obstructed by furniture or curtains.
Display looks faded when heating is activated	The heating system is less than the required minimum load. This thermostat cannot be used below that rating.

10 Technical Specifications

Power: 120/240 VAC, 50/60 Hz

Minimum load: 2 A (resistive only)
500 W @ 240 VAC
250 W @ 120 VAC

Maximum load: 16.7 A (resistive only)
2000 W @ 120 VAC
4000 W @ 240 VAC

Display range: 0°C to 60°C (32°F to 140°F)

Display resolution: 0.5°C (1°F)

Setpoint range: 5°C to 30°C (40°F to 86°F)

Setpoint interval: 0.5°C (1°F)

Storage: -20°C to 50°C (-4°F to 120°F)

Approval: c UL us

Warranty

Aube warrants this product, excluding battery, to be free from defects in the workmanship or materials, under normal use and service, for a period of three (3) years from the date of purchase by the consumer. If at any time during the warranty period the product is determined to be defective or malfunctions, Aube shall repair or replace it (at Aube's option).

If the product is defective,

- (i) return it, with a bill of sale or other dated proof of purchase, to the place from which you purchased it, or
- (ii) contact Aube. Aube will make the determination whether the product should be returned, or whether a replacement product can be sent to you.

This warranty does not cover removal or reinstallation costs. This warranty shall not apply if it is shown by Aube that the defect or malfunction was caused by damage which occurred while the product was in the possession of a consumer.

Aube's sole responsibility shall be to repair or replace the product within the terms stated above. AUBE SHALL NOT BE LIABLE FOR ANY LOSS OR DAMAGE OF ANY KIND, INCLUDING ANY INCIDENTAL OR CONSEQUENTIAL DAMAGES RESULTING, DIRECTLY OR INDIRECTLY, FROM ANY BREACH OF ANY WARRANTY, EXPRESS OR IMPLIED, OR ANY OTHER FAILURE OF THIS PRODUCT. Some provinces and states do not allow the exclusion or limitation of incidental or consequential damages, so this limitation may not apply to you.

THIS WARRANTY IS THE ONLY EXPRESS WARRANTY AUBE MAKES ON THIS PRODUCT. THE DURATION OF ANY IMPLIED WARRANTIES, INCLUDING THE WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, IS HEREBY LIMITED TO THE THREE-YEAR DURATION OF THIS WARRANTY. Some provinces and states do not allow limitations on how long an implied warranty lasts, so the above limitation may not apply to you.

This warranty gives you specific legal rights, and you may have other rights which vary from province or state to another.

Customer Assistance

If you have any questions about the product installation or operation, or concerning the warranty, contact us at:

705 Montrichard
Saint-Jean-sur-Richelieu, Quebec
J2X 5K8
Canada
Tel.: (450) 358-4600
Toll-free: 1-800-831-AUBE
Fax: (450) 358-4650
Email: aube.service@honeywell.com

For more information on our products, go to
www.aubetech.com



As an ENERGY STAR® partner, Aube Technologies has determined that this product meets the ENERGY STAR guidelines for energy efficiency.



LED T8 | T12

Notify Me when Available

[Large Project? Click here to get a volume quote.](#)



DESCRIPTION

SPECIFICATIONS

REVIEWS

EarthLED Total Product Insight

PERFORMANCE SPECIFICATIONS

REPLACEMENT FOR:	T8 OR T12 4 FOOT FLUORESCENT TUBE
BRIGHTNESS (LUMENS):	2000
COLOR TEMPERATURE:	4000K 5000K
COLOR ACCURACY (CRI):	80
DIMENSIONS	1.02" X 47.2"
POWER CONSUMPTION:	18 WATTS
VOLTAGE:	120-277 VOLTS
DIMMABLE:	NO

DIMENSIONS / ADDITIONAL DATA

CERTIFICATIONS:	UL, DESIGNLIGHTS (DLC)
PRODUCT/ORDER CODE:	4000K - 18WT8P-4F-40K-BYP 5000K - 18WT8P-4F-50K-BYP

LIFESPAN / COST TO RUN

PROJECTED LIFE: @3 HRS/DAY	50,000 HRS
YEARLY ENERGY COST: 3 HRS/DAY @ .11 KWH	\$2.17

WARRANTY

5 YEAR THINKLUX LIGHTING LIMITED WARRANTY
EARTHLED PRODUCT PROTECTION PLAN IS AVAILABLE

DirectLED - 8 Foot - LED Fluorescent Replacement Tube - Ballast Bypass - 36 Watt - 3900 Lumens - Frosted Lens

EarthLED Total Product Insight

Performance Specifications

REPLACEMENT FOR:	F96 T8, T12 8 FOOT FLUORESCENT TUBE
BRIGHTNESS (LUMENS):	3900
COLOR TEMPERATURE:	3000K 4000K 5000K 6000K
COLOR ACCURACY (CRI):	80
DIMENSIONS	1.02" X 96" (BI-PIN, SINGLE PIN) 1.02" X 93.91" (R17D)
POWER CONSUMPTION:	36 WATTS
VOLTAGE:	100-277 VOLTS
DIMMABLE:	NO

Dimensions / Additional Data

CERTIFICATIONS:	UL (G13 BI-PIN, R17D)
PRODUCT/ORDER CODE:	DL-FY-T8-2400NF-FROSTED

Lifespan / Cost To Run

PROJECTED LIFE: @3 HRS/DAY	50,000 HRS
YEARLY ENERGY COST: 3 HRS/DAY @ .11 KWH	\$4.34

WARRANTY	5 YEAR FY LIGHTING LIMITED WARRANTY EARTHLED PRODUCT PROTECTION PLAN IS AVAILABLE
----------	--

EarthLED Total Product Insight	
Performance Specifications	
REPLACEMENT FOR:	E12 CANDELABRA
BRIGHTNESS (LUMENS):	500
COLOR TEMPERATURE:	3000K 5000K
COLOR ACCURACY (CRI):	>80
TRADITIONAL WATTAGE EQUIVALENT:	60 WATTS
POWER CONSUMPTION:	7 WATTS
VOLTAGE:	120 VOLTS
DIMMABLE:	YES
MOISTURE RATING:	DAMP
FIXTURE RATING:	OPEN FIXTURES
BASE TYPE:	E12
ENERGYSTAR QUALIFIED:	YES (TKUCA38S01-7W-D-830-E12)
Dimensions / Additional Data	
BULB DIAMETER:	1.6 IN
MAXIMUM OVERALL LENGTH:	4.9 IN
PRODUCT WEIGHT:	6.7 OUNCES
CERTIFICATIONS:	UL
PRODUCT/ORDER CODE:	3000K - TKUCA38S01-7W-D-830-E12 5000K - TKUCA38S01-7W-D-850-E12
Lifespan / Cost To Run	
PROJECTED LIFE: @3 HRS/DAY	25,000 HRS
YEARLY ENERGY COST: 3 HRS/DAY @ .11 KWH	\$0.84
WARRANTY	3 YEAR THINKLUX LIMITED WARRANTY EARTHLED PRODUCT PROTECTION PLAN IS AVAILABLE



Window Jambs and Light-Duty Door Jambs

RUBBER SEAL

Part Number Example

Color: 1 (X=BLACK, OW=WHITE)
 Tape Option: 3 (BT)
 Rubber Seal Profile: 2 (X105)
 (If Applicable): 4 (SINGLE)

Single and Dual Option
 Tape Options:
 NT = No Tape
 HT = General Acrylic PSA
 BT = 3M® Bonded Tape System

"D" SECTIONS

 X2476	 X1333	 OW1333	 X1153	 X1543	 X110
 X109	 OW109	 X2507	 X119	 X125	 OW125
 X2373	 X135	 OW135	 X1750	 X2576	
 X105	 X202	 OW202	 X101	 X2338	

See page 42 for tape options

RUBBER SEAL



SEALS

"D" SECTIONS

Part Number Example



Color
1

Tape Option
3



X105 BT SINGLE
(If Applicable)

Single and Dual Option


Tape Options:

NT = No Tape


HT = General Acrylic PSA

BT = 3M[®] Bonded Tape System


2 Rubber Seal Profile




X108




OW108




X2012HT




X5381




X1458




X5272




X2828




OW2828



X2492




X1613




X1689




X2471




X1712




X1524




X2463



X1921



X5036




X2354

RUBBER SEAL




SEALS


TRIANGLE SECTIONS




X1678




X1655




2495




X2337




X2529




X2123




X2532



X2025



X1711



X1923

Adhesive Options - Choose the tape that fits your needs

"HT" GENERAL PURPOSE PRESSURE SENSITIVE ADHESIVE

This acrylic based adhesive is best used to hold the rubber seal in place while installed in a static application or compressed between two stationary objects. May be used in some light duty dynamic applications against a variety of substrates. Good heat performance -20°F. to +158°F. **Please Note:** During application ambient temperature must be above 60° F.



"BT" 3M™ HIGH STRENGTH TAPE SYSTEM

The ultimate bond between the rubber and substrate. Creates a moisture barrier and air tight seal between rubber and substrate. Highest peel and shear resistance, can be used under high loads of stress and force. Has low initial tack for easy re-positioning during installation and requires 72 hours of cure time for full bond strength. Good heat performance -20°F. to +158°F.




See our How to Install video at: www.rubber-seal-install.info



PEDESTAL SEALS



DD6109



DD1604

See page 42 for tape options

Door Bottom Sweep

(Replacement for Damaged Brush Sweep)

Product Search



DB006 Commercial Grade Door Sweep - 1-1/4" EPDM - 36"

This heavy duty commercial grade door sweep provides years of service in high traffic applications. Heavy rubber seal stands up to the elements. Fasteners are included.

SKU: 68247 CATEGORIES: [DOOR SEALS, WEATHERIZATION & THRESHOLDS](#)

WHERE TO BUY

Door Bottom Sweep

(For Doors w/ Very Large Gaps and/or Damaged Bottom Edges)



Toll Free 1.800.654.8454

[Home](#) [Products](#) [How We Can Help](#) [About](#) [Contact Us](#)

M-D BUILDING PRODUCTS

Interactive Product Catalog

M-D Building Products, Inc. > Products > DB054 Door Bottom - 1-3/4" Vinyl - 36"

Product Search

Search by name, model, or upc.

Chat ^



DB054 Door Bottom - 1-3/4" Vinyl - 36"

Energy loss through the bottom of doors can be minimized with the installation of a door bottom in conjunction with your smooth top threshold. This combination provides a weatherproof seal between the bottom of the door and the top of the threshold. Drip caps also provide your exposed entry ways protection by diverting water away from the door bottom and thresholds. M-D Building Products offers multiple combinations of new and replacement door bottoms and drip caps that will fit most entry doors.

SKU: 68593 CATEGORIES: [DOOR SEALS, WEATHERIZATION &](#)

Door Bottom Sweep

(Lower Profile)



BUILDING PRODUCTS

Toll Free 1.800.654.8454

[Home](#) [Products](#) [How We Can Help](#) [About](#) [Contact Us](#)

Interactive Product Catalog

M-D Building Products, Inc. > Products > DB002 U-Shaped Door Bottom w/Drip Cap - 1-3/8" x 36"

Product Search

Search by name, model, or upc.



DB002 U-Shaped Door Bottom w/Drip Cap - 1-3/8" x 36"



Energy loss through the bottom of doors can be minimized with the installation of a door bottom in conjunction with your smooth top threshold. This combination provides a weatherproof seal between the bottom of the door and the top of the threshold. Drip caps also provide your exposed entry ways protection by diverting water away from the door bottom and thresholds. M-D Building Products offers multiple combinations of new and replacement door bottoms and drip caps that will fit most entry doors.

SKU: 80630 CATEGORIES: [DOOR SEALS, WEATHERIZATION & THRESHOLDS](#)

Chat ^

Door Top and Side Jambs

Product Search

Search by name, model, or upc.



Cinch Door Seal Tops and Sides 42" Silver

Cinch™ Door Seal Top & Sides is a fast and easy way to save money by sealing your doors against drafts and leaks. Say goodbye to drills, screws, screwdrivers or pilot holes. Simply measure, trim, peel and stick your way to energy savings in any season. Specially developed with 3M™ Adhesive Technology, Cinch installs in mere minutes and lasts for years.

SKU: 43303 CATEGORIES: DOOR SEALS, WEATHERIZATION & THRESHOLDS TAGS: AIR-TIGHT, CINCH, ENERGY SAVINGS

WHERE TO BUY



Bottom of Garage Doors



For Questions or Concerns, Please Call


(800) 992-2018

ProSeal™ U-shaped Garage Door Bottom Seal Installation Instructions

1. Remove existing garage door bottom seal. Some garage door manufacturers will pinch the aluminum track to hold the bottom seal in place. To open a pinched track, insert a flathead screw driver, into the end of the track, and gently pry open the end, just enough to allow removal of the old door seal. Both ends of the track may need to be opened.
2. Make sure any debris in the track has been removed and that it is clean and dry. Straighten out any cramps in the track.

Quick Tip: Mix a bucket of water with some liquid dish soap or liquid laundry detergent. Place the seal in the soapy water and pull it out as you install it into the track.

3. Starting at either end of the garage door, insert the ¼" T-ends, attached to the ProSeal™ Garage Door Bottom Seal, into the track. Next, slide the ProSeal™ into the track, until it reaches the opposite side. Continue to pull the seal until you have approximately 2" protruding beyond the end of the track.
4. Leave 2" protruding on both sides, then use scissors to trim off the excess ProSeal™. If your door seal track was pinched and you wish to pinch it back together, use pliers to gently pinch the track back into place. Now tuck the 2" of excess seal back into the U-shaped opening. This will lock the seal in place.



6345 Nancy Ridge Drive, San Diego, CA 92121
(858) 625-0005 • (800) 992-2018 • Fax (858) 625-0010 • Email: info@auto-care.com




Top and Sides of Garage Doors



Roll over image to zoom in

Pemko Brush Gasketing/Door Bottom, 45-degree, Clear Anodized Aluminum with 0.625" Gray Nylon Brush insert, 0.31" width, 0.25" Height, 72" Length

[Be the first to review this item](#)

Price: **\$23.35** & **FREE Shipping** on orders over \$25—or get **FREE Two-Day Shipping** with 

Usually ships within 1 to 2 months.

Ships from and sold by Amazon.com.

New (1) from **\$23.35** & **FREE shipping** on orders over \$25.00. [Details](#)

Specifications for this item

Part Number	45061CNB72	Height	0.25 inches
Number of Items	1	Length	72 inches
UPC	086787113621	Material	Aluminum
Brand Name	Pemko	Model Number	45061CNB72
		Width	0.31 inches

Product features

- All brush seals greatly reduce the infiltration of light, air, wind, rain, and snow; prevent heat loss; control the penetration of smoke and fumes.
- The dense nylon filaments conform to the contours of every sealing surface, providing a superior seal with extremely low closing force.
- Brush remains flexible down to -40°F and has a melting point above 400°F.
- UV stabilized, dependable, long-lasting, cost-effective.
- All clear anodized brush products are supplied with gray brush

Product description

Brush Perimeter seals are designed to seal the gap between the door and the door jamb. They are surface mounted to the frame and are usually supplied with an angled flange. The angled flange provides the best contact between the brush and the surface of the door.

Product details

Shipping Weight: 9.6 ounces ([View shipping rates and policies](#))

Domestic Shipping: Currently, item can be shipped only within the U.S. and to APO/FPO addresses. For APO/FPO shipments, please check with the manufacturer regarding warranty and support issues.

International Shipping: This item is not eligible for international shipping. [Learn More](#)

ASIN: B00BU8TLNS

Item model number: 45061CNB72

Average Customer Review: [Be the first to review this item](#)

Amazon Best Sellers Rank: #754,396 in Industrial & Scientific ([See Top 100 in Industrial & Scientific](#))

#144 in Industrial & Scientific > Commercial Door Products > Commercial Door Hardware > **Trims, Seals & Gaskets**

Manufacturer's warranty can be requested from customer service. [Click here](#) to make a request to customer service.